



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300703

Miniature fuse-link

Type designation:

505

Certificate holder:

Littelfuse Inc.
O'Hare Plaza II Ste 500, 8755 W. Higgins Rd.
Chicago IL 60631
UNITED STATES OF AMERICA

The product complies with the standard(s):

EN 60127-1:2006+A1+A2
EN 60127-7:2016

Date of expiry:

17 November, 2028

EU Directive information:

According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:

Date:

21 June, 2023

Quan Li

APPENDIX:

Reference No. SE-S-2300703

Technical Data:

Type designation 505
Rated voltage (V) 450 VAC
Rated current (A) 10A; 12A
Trademark LF.
Test Report 2300166STO-001
Product information Quick-acting. Size 6,3 x 32 mm.
Pre-arcing time/current characteristic: according to manufacturer's specification.
Maximum voltage drop max.380 mV
Maximum sustained power dissipation: max. 5,5 W
Breaking capacity: 20kA at 450 VAC, power factor > 0,98
With or without wire terminations (pigtails).

Manufacturing Sites:

Suzhou Littelfuse OVS Ltd.
6 Xinghai Street, Suzhou Industrial Park, Suzhou City
Jiangsu Province 215021
CHINA

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1620079 dated 09 May 2017. A new certificate has been issued on account of renewal testing.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 21 June, 2023

Quan Li