

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

|   |   |
|---|---|
| Product   | Surge Protective Device   |
| Name and address of the applicant   | DongGuan Littelfuse Electronics Co., Ltd<br>Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,<br>China  |
| Name and address of the manufacturer                                      | DongGuan Littelfuse Electronics Co., Ltd<br>Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,<br>China  |
| Name and address of the factory   | <input type="checkbox"/> Additional information on page 2<br>DongGuan Littelfuse Electronics Co., Ltd<br>Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province,<br>China                     |
| Note: When more than one factory, please report on page 2                 |   |
| Ratings and principal characteristics                                     | Test class II / Type 2, IP66;<br>Uc = 320 V~, In = 5 kA, I <sub>max</sub> = 10 kA, I <sub>sc</sub> = 300 A;<br>Up = 1300 V (L-N), Up = 1800 V (L-PE, N-PE);<br>Maximum overcurrent protection: 20 A gG fuse |
| Trademark (if any)  |   |
| Customer's Testing Facility (CTF) Stage used                              |   |
| Model / Type Ref.   | LSP05G277SXXXXX   |
| Additional information (if necessary may also be reported on page 2)      | <input type="checkbox"/> Additional information on page 2<br>This certificate replaces NL-40516 dated on 2016-03-30 due to technical modification.  |
| A sample of the product was tested and found to be in conformity with     | IEC 61643-11:2011<br>National differences:<br>EU Group Differences<br>3182815.50 and 6094457.51   |
| As shown in the Test Report Ref. No. which forms part of this Certificate |   |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands