

접수번호 : 16-039609-02
(Receipt No.)



전기용품안전인증서

Electrical Appliances Safety Certificate

안전인증번호 (Certificate No.)	: SU05024-7014B
제조사명 (Manufacturer)	: Littelfuse Phils.Inc
대표자명 (President)	: Eduardo Bagadion
제조공장의 주소 (Factory Address)	: Lima Technology Center, Special Economic Zone Lipa City- Malvar, Batangas, Philippines
제품명 (Product)	: 퓨즈(Sub-miniature fuse-links)
기본모델명 (Basic Model)	: 392 250V 2A
정격 (Rating)	: 250V 2A 35A
파생모델명 (Series Model)	: See the attachment 2
적용기준 (Standard)	: KC60127-3(2015-09), K60127-1(2011-12)

「전기용품안전 관리법 시행규칙」 제6조제2항에 따라 위의 전기용품에 대하여 안전인증서를 발급합니다.

We Issue Electrical Appliances Safety Certification as above product by Article 6 Section 2 of the Electrical Appliances Safety Control Law Enforcement Regulation.

2016 년 08 월 05 일
Year month day



한국산업기술시험원
KOREA TESTING LABORATORY



※ 이 인증서는 「전기용품안전 관리법」에 따른 전기용품 안전성 확인에 한정된 것이며, 그 밖의 다른 법률이 적용되는 제품의 경우에는 해당 법률에 따라 추가로 인증·허가 등을 받아야 합니다.

- 첨부 :
(Annex)
1. 안전관리부품 및 재질목록 (List of Critical Components)
 2. 기본모델·파생모델의 내용 (Descriptions of the basic and series model)
 3. 전기용품안전인증의 변경 현황 (Revisions Status)

첨부 2 : 기본모델 · 파생모델의 내용
General descriptions of Certified Products

파생모델명 Derivative model	기본모델과의 차이점 Differences between the basic and derivative model(s)
392 250V 1A	Rated current is changed(250 V 1 A 35 A)
392 250V 1.25A	Rated current is changed(250 V 1.25 A 35 A)
392 250V 1.6A	Rated current is changed(250 V 1.6 A 35 A)
392 250V 2.5A	Rated current is changed(250 V 2.5 A 35 A)
TE5 369 250V 1A	Rated current is changed(250 V 1 A 35 A)
TE5 369 250V 1.25A	Rated current is changed(250 V 1.25 A 35 A)
TE5 369 250V 1.6A	Rated current is changed(250 V 1.6 A 35 A)
TE5 369 250V 2A	Model name is changed(250 V 2 A 35 A)
TE5 369 250V 2.5A	Rated current is changed(250 V 2.5 A 35 A)
392B 250V 1A	Rated current is changed(250 V 1 A 35 A), Color(Black) is different.
392B 250V 1.25A	Rated current is changed(250 V 1.25 A 35 A), Color(Black) is different.
392B 250V 1.6A	Rated current is changed(250 V 1.6 A 35 A), Color(Black) is different.
392B 250V 2A	Color(Black) is different.
392B 250V 2.5A	Rated current is changed(250 V 1 A 35 A), Color(Black) is different.
제품특기사항 및 시험조건 Remarks & Test conditions	
<p>1. Review Report Ref. No.: 07-1920-4192 (2007.10.01.) Test Report Ref. No.: No.2007TS01595 (KERI: 2007.09.05.)</p> <p>2. Products Description</p> <ul style="list-style-type: none"> - 250 V 2 A 35 A - Plastic case - Time-lag type - Standard sheet 4 	
<p><input type="checkbox"/> 본 제품의 시험내용에 관하여 문의하실 사항이 있으시면 아래 연락처로 문의하시기 바랍니다. 시험담당자: 인증지원본부 전기부품평가센터 임화준 / (055) 791-3431</p> <p><input type="checkbox"/> If you have any question on product testing, please contact the person below : Job holder : Certification Business Division, Electrical Components Testing Center H.J Rim /+82 55 791-3431</p>	

FP511-09-00